

# Fire Hoods & Downlight Covers



## DESCRIPTION

**FIREFLY® Hoods and Downlight Covers** are designed to provide fire protection over the recessed luminaire or downlight in a fire rated ceiling.

In the event of a fire the **Fire Hood or Downlight Covers** will delay the progress of fire and smoke travelling through a ceiling, thereby providing precious time for occupants to safely exit the building and emergency services to minimise fire damage.

|                |                                                                                                                                                                                                                                                                                                                                                        |
|----------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| DESCRIPTION    | Lightweight fire protective cover suitable for recessed luminaires or downlights of various sizes                                                                                                                                                                                                                                                      |
| CERTIFICATION  | Third Party Certified by IFCC. Certificate number: IFCC 1564                                                                                                                                                                                                                                                                                           |
| APPLICATION    | Can be installed from above or below                                                                                                                                                                                                                                                                                                                   |
| SPECIFICATION  | <p>BS476 Part 23:1987, clause 5 – 60 minutes</p> <p>Assessed for use with plasterboard – 60 minutes</p> <p>Suitable for use under timber floors, assembly with plasterboard &amp; suspended ceiling system – 60 minutes</p> <p>Suitable for use under timber floor</p> <p>Assembly protected with fire-rated suspended ceiling system – 30 minutes</p> |
| CLASSIFICATION | <p>BS 476 Class “0” BUILDING REGULATIONS – Complies with requirements</p> <p>BS 476 Part 6 Fire Propagation test – Fire propagation index 2.56</p> <p>BS 476 Part 7 surface spread of flame – Certification to “class1” pass</p>                                                                                                                       |

